

## Chapter 7 - POLYCHLORINATED BIPHENYLS POLICY

**NOTE:** The current version of this Chapter is maintained and approved by the Environmental Management Office (EMO). The revision date for this chapter is November 2003. If you are referencing paper copies, please verify that it is the most current version before use. The current version is maintained on the Glenn Research Center intranet at <http://osat-ext.grc.nasa.gov/emo/pub/epm/epm-contents.pdf>. Approved by: EMO Chief, Michael Blotzer {mailto:Michael.J.Blotzer@grc.nasa.gov}

### PURPOSE

This chapter establishes policies pertaining to the handling and disposal of polychlorinated biphenyls (PCB's) at GRC. This chapter conforms to the GRC EMS as defined in Environmental Programs Manual [Chapter 1](#). This chapter supports GRC Environmental Policy, which promotes pollution prevention, regulatory compliance, and continuous improvement.

Following the guidelines in this chapter will help achieve some of the GRC environmental objectives and targets such as the reduction of spills and releases, the identification and implementation of pollution prevention activities, and the reduction of solid waste generation. Achievement of these targets can be tracked through the following record(s) Emergency Incident Reports, P2 Committee & Plan Results, number of regulatory non-compliances found, and the number of reduction, reuse, or recycling opportunities identified.

### APPLICABILITY

The guidance provided in this chapter is applicable to GRC employees and contractors at all levels who are in any way involved in the handling, storage, transportation, and/or disposal of PCB's.

### DEFINITIONS

Annual document log

A record of waste handling at a facility.

Quarterly inspection

A visual inspection for leaks from PCB transformers conducted once every three months.

PCB transformer (PCB item)

A transformer with a PCB concentration above 500 ppm.

PCB-contaminated transformer (PCB item)

A transformer with a PCB concentration between 50 and 500 ppm.

PCB article

Any manufactured article, other than a PCB container, that contains PCB's and PCB items.

PCB article container

A device containing PCB's or PCB articles whose surfaces have not been in direct contact with PCB's (example: a drum containing a non-leaking capacitor).

PCB container

A device containing PCB's or PCB articles whose surfaces have been in direct contact with PCB's (example: a drum containing a leaking capacitor).

PCB item

A PCB article, PCB container, PCB article container or PCB equipment container that contains PCB's.

PCB equipment

A manufactured item other than a PCB container, PCB article container, or which contains, a PCB Article (example: fluorescent light ballast).

## **BACKGROUND**

GRC has 13 electrical substations. Transformers are also spread out over a variety of locations throughout the lab (see Table III of the Environmental Spill and Contingency Plan.) There are no PCB transformers on site. Light ballasts are removed on an ongoing basis, when required. These ballasts, capacitors, small transformers, and other possible PCB-contaminated material are stored in Building 136 before shipment. Annual documents can be found in Building 6, Room 129.

## **POLICY**

It is GRC policy to maintain information such as inspection logs, annual document logs, and disposal records in a readily accessible manner and to dispose of PCB articles in compliance with Federal and State regulations.

## **REQUIREMENTS**

- 40 CFR 761 - Polychlorinated Biphenyls Manufacturing, Processing, Distribution in Commerce, and Use Prohibitions
- 40 CFR 112 - Oil Pollution Prevention
- 29 CFR 1910 - Occupational Safety and Health Standards
- 15 USC 2605
- 63 FR 3538-35474 of 6-29-98

## **PROCEDURES**

Facilities Division (FD)

- Disposes of PCB items through the Waste Management Team.
- Conducts weekly inspections of Building 136.
- Assists Plum Brook with disposal of PCB items.

## **ENVIRONMENTAL MANAGEMENT OFFICE**

Environmental Team (ET)

- Writes and maintains PCB annual document log for GRC.
- Conducts internal audits of the GRC PCB program.
- Keeps PCB-related records in a readily accessible location.

Waste Management Team (WMT)

- Assists FD with disposal of PCB items
- Assists Plum Brook with disposal of PCB items
- Conducts monthly inspections of the PCB storage area.

## Plum Brook Station

Manages its own PCB disposal, inspection, and record keeping system independently with technical advice from FD and ET. Records of interest include such things as disposal records and annual document logs.

### **RECORDS**

- PCB Annual Document Logs

### **REFERENCES**

40 CFR 761 Polychlorinated Biphenyls (PCBs) manufacturing, processing, distribution in commerce, and use prohibitions.

---

Safety and Assurance Directorate ([SAAD](#))

Environmental Management Office Chief, Michael Blotzer

Chapter Lead: Daniel Papcke {<mailto:Daniel.A.Papcke@nasa.gov>}

Web Curator: Sandra Jacobson, SAIC {<mailto:Sandra.Jacobson@grc.nasa.gov>}

Revision Date: November 2003

PROCEDURES/PROCESS DESCRIPTION

